



**Purchasing Division**  
2101 O'Neil Avenue, Room 309  
Cheyenne, WY 82001  
307-773-1045  
tbarttelbort@cheyennecity.org

**ADDENDUM NUMBER ONE**  
**BID S-14-19**

To: All Prospective Bidders and all others concerned

From: City of Cheyenne, Purchasing Manager, TJ Barttelbort

Date: March 5, 2019

**Subject: Addendum Number One to Bid S-14-19 for the Jr. League Dugout Roof Replacements and Masonry Repairs**

---

The changes, clarifications, omissions, additions, and/or alterations in, on, and to the bid information and specifications shall apply to the Invitation For Bid submitted for and to the project indicated above. Except as modified by this Addendum Number One, all of the terms and provisions of the Invitation for Bid for the above listed project remain in full force and effect. This Addendum Number One supersedes all previous instructions pertaining to the items listed:

Clarifications and Updates to the Bid Specifications are found below:

1. Per Page 12, 24.00 PERMITS AND LICENSES: The Contractor shall obtain all permits necessary to execute the work. Fees will be waived for permits issued by the City. Permits may be required by other entities which are not furnished or paid for by the City. The successful bidder and its subcontractors shall be required to hold and pay for any licenses required and shall also pay for all public utility charges.
2. The Contractor may drive on the turf, however it will be the Contractor's responsibility to repair any damage created by doing so, to include but not limited to: rut marks, broken sprinkler heads, or broken irrigation control boxes. The City of Cheyenne can mark irrigation control boxes or sprinkler heads, if requested by the Contractor.
3. Page 48, 1, a: All dugout roofs may be removed before starting installation of new roofs.
4. Page 48, 1, b, ii: Use minimum 29-gauge metal roofing and **1" OSB Decking**.
5. Page 48, 1, c: Sealant shall be applied to all untreated, exposed wood surfaces, to include exposed wood surface of all new OSB roof sheathing.

**ADDENDUM ONE ACKNOWLEDGED:**

BY \_\_\_\_\_ TITLE \_\_\_\_\_

(Addendum **must** be signed and returned with bid or receipt of the addendum **must** be acknowledged on the Invitation to Bid).