



**City of Cheyenne - Purchasing**  
2101 O'Neil Avenue, Room 309  
Cheyenne, WY 82001  
307-773-1045  
tbarttelbort@cheyennecity.org

## **ADDENDUM NUMBER ONE**

### **BID S-10-21**

To: All Prospective Bidders and all others concerned

From: City of Cheyenne, Purchasing Manager, TJ Barttelbort

Date: February 10, 2021

**Subject: Addendum Number One to Bid S-10-21 for the 2021 City Overlay Part 1 Project**

---

The changes, clarifications, omissions, additions, and/or alterations in, on, and to the bid information and specifications shall apply to the Invitation For Bid submitted for and to the project indicated above. Except as modified by this Addendum Number One, all of the terms and provisions of the Invitation for Bid for the above listed project remain in full force and effect. This Addendum Number One supersedes all previous instructions pertaining to the items listed:

#### **Questions & Responses**

- Q1: Will construction survey, provided by the contractor, be required?
- A1: No professional survey will be required however, in areas that require long sections of full removal, off-set control staking may need to be utilized. In addition, a transit level may be required to ensure adequate flow for curb and gutter.
- Q2: To clarify from the pre-bid meeting – We will not have to shut down during CFD.
- A2: That is correct, we will not be required to shut down during CFD.
- Q3: Will liquidated damages be assessed if the low bid contractor goes past 10/31/21.
- A3: Yes, Liquidated Damages will be assessed if the project is not completed by the Contracted time for completion per contract details.
- Q4: Can the “W” base be local aggregate?
- A4: Yes

Q5: On bid item 02210, Unclassified Excavation, what is the depth of the W base or does it match the CY volume of the excavation?

A5: It matches the CY volume of the excavation.

Q6: Will the asphalt binder for the patching items be PG 64-28?

A6: Yes

Q7: Will the APAT that occurs behind driveways need to be "T" Patched?

A7: "T" patches at private driveways will not be required due to the typical thickness of material.

Q8: Will all the Cul-de-Sac's that have R&R Concrete on them be milled and overlaid as well?

A8: All Cul-de-Sacs listed and drawn on plans are scheduled for full width mill and overlay.

**ADDENDUM ONE ACKNOWLEDGED:**

BY \_\_\_\_\_ TITLE \_\_\_\_\_

(Addendum **must** be signed and returned with bid or receipt of the addendum **must** be acknowledged on the Invitation to Bid).

**REMAINDER OF PAGE INTENTIONALLY LEFT BLANK**