



City of Cheyenne - Purchasing
2101 O'Neil Avenue, Room 309
Cheyenne, WY 82001
307-773-1045
tbarttelbort@cheyennecity.org

ADDENDUM NUMBER ONE
BID S-3-21

To: All Prospective Bidders and all others concerned

From: City of Cheyenne, Purchasing Manager, TJ Barttelbort

Date: September 18, 2020

Subject: Addendum Number One to Bid S-3-21 for the East 12th Street and Meadow Drive Mill and Overlay project

The changes, clarifications, omissions, additions, and/or alterations in, on, and to the bid information and specifications shall apply to the Invitation For Bid submitted for and to the project indicated above. Except as modified by this Addendum Number One, all of the terms and provisions of the Invitation for Bid for the above listed project remain in full force and effect. This Addendum Number One supersedes all previous instructions pertaining to the items listed:

Questions & Responses

- Q1: Can curb patches be patched with alluvial aggregate since they will be milled and overlaid?
- A1: We will allow alluvial aggregate asphalt on the two foot patches for curb replacement only.
- Q2: Granite is not being specified for concrete and base as it is for asphalt?
- A2: Granite aggregate is not required for the concrete or base material.
- Q3: Are you going to accept L Base in place of W if needed?
- A3: We will allow grading L material for fill in the case of unclassified excavation in excess of six inches in depth.

- Q4: Is there any wydot funding or special paper work that needs submitted with bid? Can you supply bid check list.
- A4: Bid S-3-21 is not being funded with WYDOT funding, therefore WYDOT paperwork is not required. A bid checklist has already been included with Bid S-3-21 on Page 22.
- Q5: When will project be awarded and when can the contractor start?
- A5: **Tentative** Project Schedule Follows:
- | | |
|------------------------------|---|
| Bid Opening: | 10/5/2020 |
| City Review: | 10/5/2020 – 10/7/2020 |
| Letter of Intent to Award: | 10/7/2020 |
| Finance Committee: | 10/19/2020 |
| Final City Council Approval: | 10/26/2020 |
| Contract Paperwork / Bonds: | 10/27/2020 – 10/30/2020 (Dependent on Contractor) |
| Notice to Proceed: | Upon receipt of fully executed Contracts |
- Q6: Is there a detail for landscape curb?
- A6: Yes, please refer to the City of Cheyenne and Board of Public Utilities Construction Specifications and Standard Drawings, Standard Drawing No. 03340-03, Section A-A.

ADDENDUM ONE ACKNOWLEDGED:

BY _____ TITLE _____
 (Addendum **must** be signed and returned with bid or receipt of the addendum **must** be acknowledged on the Invitation to Bid).

REMAINDER OF PAGE INTENTIONALLY LEFT BLANK