



City of Cheyenne - Purchasing
2101 O'Neil Avenue, Room 309
Cheyenne, WY 82001
307-773-1045
tbarttelbort@cheyennecity.org

ADDENDUM NUMBER TWO BID S-11-23

To: All Prospective Bidders and all others concerned

From: City of Cheyenne, Purchasing Manager, TJ Barttelbort

Date: January 17, 2023

Subject: **Addendum Number Two to Bid S-11-23 for 2023 City Overlay Part #2**

The changes, clarifications, omissions, additions, and/or alterations in, on, and to the bid information and specifications shall apply to the Invitation For Bid submitted for and to the project indicated above. Except as modified by this Addendum Number Two, all of the terms and provisions of the Invitation for Bid for the above listed project remain in full force and effect. This Addendum Number Two supersedes all previous instructions pertaining to the items listed:

QUESTIONS AND RESPONSES:

Q1: Can you please define what Alley Rock is?

A1: Per the City's Standard Construction Specifications, SECTION 02227, ALLEY AND GRAVEL STREET RESTORATION:

PART 2 PRODUCTS

2.01 MATERIALS

A. ALLEY ROCK

1. Alley rock shall consist of a hard durable, crushed, natural stone. Alley rock shall be of such gradation that one hundred (100) percent shall pass the one and one half (1-½) inch sieve and no less than ninety (90) percent by weight shall be retained on a three-quarter (¾) inch sieve.

*Note: Type 57 rock may be substituted in lieu of the above gradation.

2. Grading "W" base as defined in SECTION 02190. Recycled concrete base may be used when gradation meets the gradation requirements of Grading "W".

ADDENDUM TWO ACKNOWLEDGED:

BY _____ TITLE _____

(Addendum **must** be signed and returned with bid or receipt of the addendum **must** be acknowledged on the Invitation to Bid