

NOTES:


1. THE CONTRACTOR SHALL FURNISH ALL REDUCERS/ADAPTERS OR ANY OTHER FITTINGS REQUIRED TO CONNECT THE NEW SERVICE LINE TO THE EXISTING SERVICES OR METER PIT.
2. ALL METER PITS INSTALLED IN DECORATIVE STONE, MULCH OR FLOWER BEDS SHALL BE INSTALLED 2" ABOVE GRADE.
3. ALL METER PITS INSTALLED IN GRASS, GRAVEL OR PAVEMENT SHALL BE INSTALLED AT GRADE.
4. IF SURFACE IS NOT TO FINAL GRADE AT TIME OF INSTALLATION OF METER, OWNER MUST RAISE OR LOWER PIT WHEN SURFACE IS GRADED.
4. METER PIT SHALL BE SET ON OWNER'S PROPERTY 1' BEHIND PROPERTY LINE.
5. NO IRRIGATION SYSTEM FITTINGS, VALVES OR OTHER NON-SERVICE RELATED PLUMBING SHALL BE ALLOWED IN METER PIT.
6. NO PRESSURE RELIEF VALVE SHALL BE ALLOWED IN THE METER PIT.
7. 1-7/8" HOLE IS REQUIRED IN COVER FOR TOUCH PAD.

| | 1 1/2" METER | | 2" METER | |
|--|--------------------------|-------------------------|--------------------------|-------------------------|
| | MUELLER/HUNT | FORD | MUELLER/HUNT | FORD |
| METER PIT | 500VB-3660-FFBN | PSBB-688-36HB-60-SB4-NL | 550VB-3660-FFBN | PSBB-788-36HB-60-SB4-NL |
| TOUCH READ LID & FRAME & EXTENSION RING | 780113 & 700098 & 790438 | MC-36-REC-T | 780113 & 700098 & 790438 | MC-36-REC-T |
| NOT RATED FOR TRAFFIC AREAS. REFER TO DRAWING 02665-15 FOR ACCEPTABLE TRAFFIC RATED METER PIT. | | | | |



CITY OF CHEYENNE
AND
BOARD OF PUBLIC
UTILITIES
STANDARD DRAWING

WATER METER PIT DETAIL
FOR 1-1/2" AND 2" LINES



REVISED
2022

STANDARD
DRAWING NO.
02665-14